



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS2 080971 0012 Rev. 00

Initial No. -

Certificate Holder: JRP & ASSOCIATES PTE LTD
18 Tampines Industrial Crescent
#07-05, Space@Tampines
Singapore 528605
SINGAPORE

UEN - 199900007M

Product: Roof Covering Materials

Brand Name: JAS PANEL

Model(s): JCOM

Product Details: Rating: Class 0
Thickness: 10mm
Area Density: 5.8kg/m²
Tested on the PVDF coating (Grey) face

Standard(s): BS 476-6:1989/A1:2009
BS 476-7:1997

Country of Origin: People's Republic of China

Test Report(s): 7191313724-MEC23/B1-YWA & 7191313724-MEC23/B2-YWA

Valid until: 2029-02-07

Page 1 of 1

Issued on: 2024-02-08

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg