





PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLS2 080971 0010 Rev. 00

Initial No. CLS2 12 12 80971 001

**Product Details:**

Product details as per table below

Thickness (mm)	Bulk Area Density (kg/m <sup>2</sup> )
4	7.6
6	10.4

Page 2 of 2

Issued on: 2019-11-05

Vice-President (Certification Department)  
TÜV SÜD PSB



This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations, TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at [www.tuv-sud-psb.sg](http://www.tuv-sud-psb.sg).